

	MOD. CALDAIA		PORTATA TERMICA				POTENZA TERMICA				RENDIMENTI			TIPI DI APPARECCHI
			nominale		minima		nominale		minima		Comb	Utile 100%	Utile 30%	
			kW	kcal/h	kW	kcal/h	kcal/h	kW	kcal/h	kW				
ISTANTANEE BITERMICHE	RBE 22		26,60	22900	11,50	9890	23,70	20380	9,75	8387	92,20	89,10	85,90	B11BS
	RSBE 22		26,60	22900	11,50	9890	24	20657	9,55	8209	90,84	90,30	86,30	B22 C12 C32 C42 C52
SOLO RISCALDAM.	RRE 23N		26,60	22900	13,30	11438	23,54	20245	12	10300	92,50	88,50	90,40	B11BS
	RSER 22		26,60	22900	12,80	11000	24,34	20900	11	9450	93,70	91,50	87,10	C12 C32 C42 C52 (C62 only NL)
	RSER 23/3S		26,60	22900	13,30	11438	24,74	21275	12,18	10477	94,70	93,00	92,10	C12 C32 C42 C52
ISTANTANEE	RE 22		26,60	22900	12,80	11000	23,90	20550	10,90	9370	91,80	90,00	85,80	B11BS
	RE 23N		26,60	22900	13,30	11438	23,54	20245	12	10300	92,50	88,50	90,40	B11BS
	RSE 22		26,60	22900	12,80	11000	23,76	20434	10,50	9061	93,70	92,60	88,30	C12 C32 C42 C52 (C62 only NL)
	RSE 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
	RSE 32		34,50	29670	19	16340	31,90	27445	16,93	14556	93,20	92,50	90,50	C12 C32 C42 C52
	RSE 23/3S		26,60	22900	13,30	11438	24,74	21275	12,18	10477	94,70	93,00	92,10	C12 C32 C42 C52
AD ACCUMULO	RAE 27		29,80	25628	17,50	15000	26,68	22950	15,06	12950	91	89,50	86,50	B11BS
	RAE 23N		26,60	22900	13,30	11438	23,54	20245	12	10300	92,50	88,50	90,40	B11BS
	RSAE 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
	RSAE 32		34,50	29670	19	16340	31,90	27445	16,93	14556	93,20	92,50	90,50	C12 C32 C42 C52
	RSAE 23/3S		26,60	22900	13,30	11438	24,74	21275	12,18	10477	94,70	93,00	92,10	C12 C32 C42 C52
PREMISC. A CONDENS.	BK 25	80°/60°	25	21500	9	7740	24,60	21156	8,73	7508	98,50	98,40	100,10	C13 C33 C43 C53 C63 C83
		50°/30°					26,67	22940				106,70	106,30	C13 C33 C43 C53 C63 C83
	BKR 25	80°/60°	25	21500	9	7740	24,60	21156	8,73	7508	98,50	98,40	100,10	C13 C33 C43 C53 C63 C83
		50°/30°					26,67	22940				106,70	106,30	C13 C33 C43 C53 C63 C83
	BKA 25	80°/60°	25	21500	9	7740	24,60	21156	8,73	7508	98,50	98,40	100,10	C13 C33 C43 C53 C63 C83
		50°/30°					26,67	22940				106,70	106,30	C13 C33 C43 C53 C63 C83
	BKA 100	80°/60°	25	21500	9	7740	24,60	21156	8,73	7508	98,50	98,40	100,10	C13 C33 C43 C53 C63 C83
		50°/30°					26,67	22940				106,70	106,30	C13 C33 C43 C53 C63 C83
PER INSTALLAZ. ALL' ESTERNO	RSBE 22H		26,60	22900	11,50	9890	24	20657	9,55	8209	90,84	90,30	86,30	B22 C12 C32 C42 C52
	RSHE 22		26,60	22900	12,80	11000	24,34	20900	11	9450	93,70	91,50	87,10	C12 C32 C42 C52 (C62 only NL)
	RSHE 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
INSTALLAZ. ALL' ESTERNO INCASSATE A MURO	RSBE 22X		26,60	22900	11,50	9890	24	20657	9,55	8209	90,84	90,30	86,30	B22 C12 C32 C42 C52
	RSEX 22		26,60	22900	12,80	11000	23,76	20434	10,50	9061	93,70	92,60	88,30	C12 C32 C42 C52 (C62 only NL)
	RSEX 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
	RSAX 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
A BASAMENTO	RABE 27		29,80	25628	17,50	15000	26,68	22950	15,06	12950	91	89,50	86,50	B11BS
	RABE 32		34,90	30014	19,80	17028	31,44	27040	17,06	14678	91,70	90,10	87	B11BS
	RABE 127		29,80	25628	17,50	15000	26,68	22950	15,06	12950	91	89,50	86,50	B11BS
	RSAB 27		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
	RSAB 127		29,80	25628	17,50	15000	26,85	23090	15	12900	91,50	90,10	87,50	C12 C32 C42 C52
BLOWSPLIT	RSER 27H		29,80	25628	17,50	15000	27,29	23475	15,34	13199	91,90	91,60	89,10	C12 C32 C42 C52
	RSER 32H		34,50	29670	19	16340	31,90	27445	16,93	14556	93,20	92,50	90,50	C12 C32 C42 C52

MOD. CALDAIA	PERDITE AL CAMINO %		PERDITE AL MANTELLO %		TEMP. FUMI °C		PORTATA FUMI Kg/h		CO2 %		CO ppm		Emissioni NOx UNI EN 297	Direttiva Rendimenti 92/42CEE
	Pot nom.	Pot. rid.	Pot nom.	Pot. rid.	Pot nom.	Pot. rid.	Pot nom.	Pot. rid.	Pot nom.	Pot. rid.	Pot nom.	Pot. rid.	Classe	Numero Stelle
RBE 22	7,80	12,25	3,10	2,95	114	85,4	0,0216	0,0228	5,02	2,03	33	26	II	★
RSBE 22	9,16	16,53	0,54	0,47	139	105,5	0,0205	0,0238	5,34	2,03	30	34	II	★★
RRE 23N	7,50	8,13	4	1,87	111,5	74,1	0,0208	0,0186	5	2,68	21	9	IV	★
RSER 22	6,30	10,40	2,20	3,70	121,8	100,5	0,0147	0,0155	7,17	3,14	46	14	I	★
RSER 23/3S	5,30	7,55	1,70	1,50	121,8	87,40	0,0130	0,0155	8,45	3,52	39	33	V	★★★
RE 22	8,20	11,10	1,10	1	114	87	0,0227	0,0216	4,80	2,40	31	38	II	★
RE 23N	7,50	8,13	4	1,87	111,5	74,10	0,0208	0,0186	5	2,68	21	9	IV	★
RSE 22	6,30	11,20	2,20	3,70	113,8	95,60	0,0176	0,0191	6,20	2,60	33	17	I	★★
RSE 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RSE 32	6,80	10,40	0,70	0,40	119,6	100,3	0,0225	0,0128	6,35	3,13	56	46	II	★★
RSE 23/3S	5,30	7,55	1,70	1,50	121,8	87,40	0,0130	0,0155	8,45	3,52	39	33	V	★★★
RAE 27	9	12,8	1,50	1,20	120	99	0,0233	0,0261	4,60	2,45	10	0	I	★
RAE 23N	7,50	8,13	4	1,87	111,5	74,10	0,0208	0,0186	5	2,68	21	9	IV	★
RAE 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RAE 32	6,80	10,40	0,70	0,40	119,6	100,3	0,0225	0,0128	6,35	3,13	56	46	II	★★
RAE 23/3S	5,30	7,55	1,70	1,50	121,8	87,40	0,0130	0,0155	8,45	3,52	39	33	V	★★★
BK 25	1,50	2,40	0,10	0,70	74	68	0,0114	0,004	9,40	8,70	98	16	V	★★★★
BKR 25	1,50	2,40	0,10	0,70	74	68	0,0114	0,004	9,40	8,70	98	16	V	★★★★
BAK 25	1,50	2,40	0,10	0,70	74	68	0,0114	0,004	9,40	8,70	98	16	V	★★★★
BAK 100	1,50	2,40	0,10	0,70	74	68	0,0114	0,004	9,40	8,70	98	16	V	★★★★
RSBE 22H	9,16	16,53	0,54	0,47	139	105,5	0,0205	0,0238	5,34	2,03	30	34	II	★★
RSHE 22	6,30	10,40	2,20	3,70	121,8	100,5	0,0147	0,0155	7,17	3,14	46	14	I	★★
RSHE 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RSBE 22X	9,16	16,53	0,54	0,47	139	105,5	0,0205	0,0238	5,34	2,03	30	34	II	★★
RSEX 22	6,30	11,20	2,20	3,70	113,8	95,6	0,0176	0,0191	6,20	2,60	33	17	I	★★
RSEX 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RSAX 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RABE 27	9	12,80	1,50	1,20	120	99	0,0233	0,0261	4,60	2,45	10	0	I	★
RABE 32	8,30	10,80	1,60	3	115	94	0,0283	0,0272	4,80	2,75	24	5	I	★
RABE 127	9	12,80	1,50	1,20	120	99	0,0233	0,0261	4,60	2,45	10	0	I	★
RSAB 27	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RSAB 127	8,50	13,50	1,40	1,32	151	130	0,0183	0,0216	6,70	3,30	39	10	I	★★
RSER 27H	8,10	12	0,30	0,30	141	121	0,0199	0,0221	6,37	3,33	39	10	I	★★
RSER 32H	6,80	10,40	0,70	0,40	119,6	100,3	0,0225	0,0128	6,35	3,13	56	46	II	★